



**DEPARTMENT OF PUBLIC HEALTH & PREVENTIVE MEDICINE**  
**THE TAMIL NADU EDUCATION ACT, Rule 24 – APPENDIX - 3**  
**(Form of Sanitary Certificate)**

HUD : RAMANATHAPURAM

BLOCK : RAMANATHAPURAM

R.NO : 3872/A7/2025

Dated : 14.08.2025

I hereby declare that I have caused to be inspected **SYED AMMAL PUBLIC SCHOOL(CBSE),PERAVOOR, RAMANATHAPURAM DT.** the Building and premises on 13.08.2025 and certify that,


- 1.The accommodation provided is sufficient for the maximum number of Pupil taught there in.
2. The accommodation is properly ventilated and lighted for the proposed building,
3. The proposed building is maintained neat and clean,
4. The supply of drinking water is wholesome,
5. The latrine arrangements are adequate and satisfactory for the proposed building.


The Conditions mentioned in the Enclosure should be strictly followed, and if any violation/deviation of the above said conditions were found, this certificate will be liable for cancellation.


Date of issue : 14.08.2025

Valid upto : 13.08.2026

3825  
Block Health Supervisor  
GPHC/Devipattinam  
Ramanathapuram Block

  
Deputy Director of Health Services  
Ramanathapuram

  
Correspondent  
Syed Ammal Public School,  
Peravoor,  
Ramanathapuram.

  
Principal  
Syed Ammal Public School,  
Peravoor,  
Ramanathapuram.

**CONDITIONS:**

1. Environment should be kept free from mosquitoes breeding
2. Safe drinking water must be provided to all individuals.
3. All water storage containers and tanks should be kept tightly closed and maintained clean.
4. Septic tank Air pipe should be covered with mosquito net.
5. First aid box with necessary medicines should be kept ready for use.
6. Hall buildings should be constructed as per the plan approval enclosed with the application and submitted in this office.
7. No-objection certificate should be obtained from this office, if any alteration or modification in the existing building and additional building or new building is to be constructed.
8. Properly maintain fire safety equipment and educate the employees about its operation.
9. The building premises must be kept neat and clean always.
10. Toilets and Urinals must be kept hygienically clean
11. There shall not be any thatched structure in the premises.
12. The building maintenance and repairs should be done then and there immediately.
13. Basket for disposal of sanitary napkins should be provided in ladies toilets.
14. If any communicable disease or suspected disease is found among the employees in premises, it must be immediately informed to the concerned PHC Medical Officer.
15. Sanitary certificate may be cancelled if any discrepancies or deviations are found in future during inspection.
16. No smoking area " Smoking here is an offence " signage board to be displayed at prominent places as per COTPA, act 2003.

**PERFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION**

**CERTIFICATE**

**NO: 174/ GPHC/ DEVIPATTINAM/ Dt.20/06/2025**


**DATE:20-06-2025**


This is to Certified that inspection term headed By **A. Veeraperumal**,  
**BLOCK HEALTH SUPERVISOR** from govt Primary health Centre, Devipattinam,  
Inspected The **SYED AMMAL PUBLIC SCHOOL (CBSE)** Palankulam , Peravoor,  
Ramanathapuram – DIST – 623504 On 20.06.2025 and found. That The **SYED**  
**AMMAL PUBLIC SCHOOL (CBSE), PALANKULAM, Peravoor, Ramanathapuram – DIST**  
– 623504 has safe drinking water facilities for the students and members of staff of  
the institution and is maintained. The Hygiene Sanitation Condition in the school  
building and the campus as per the norms prescribed by the CENTRAL STATE/U.T  
GOVT.The Above certified is Valid for a period of 21.06.2025 TO 21.06.2026

Chlorination during inspection : <sup>2.5</sup> ~~2.45~~ **PM** ~~pm~~

**TO:**  
**SYED AMMAL PUBLIC SCHOOL, (CBSE)**  
**Palankulam,**  
**Peravoor,**  
**Ramanathapuram – Dist -623504**

**A. VEERAPERUMAL**  
Block Health Supervisor &  
Block Registrar (Birth & Death)  
GPHC - Devipattinam,  
Ramanathapuram Block.

  
**Correspondent**  
**Syed Ammal Public School,**  
**Peravoor,**  
**Ramanathapuram.**

  
**Principal**  
**Syed Ammal Public School,**  
**Peravoor,**  
**Ramanathapuram.**



# TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

## DISTRICT WATER TESTING LABORATORY

OM Sakthi Nagar, 1st Street, Near VAO Office,

Ramanathapuram – 623 504., E-mail: ramnaddistrictlab@gmail.com



TC-15576

### TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	DWTL/TR/2026/27993-1	Report Issue Date :	22.01.2026	Page No : 1 of 1
Invoice Details:	307/Dt.21.01.2026 Amt.Rs.1180 / -	ULR No :	TC155762600000098F	

Client Name & Address Contact No / Email.ID	: Syed Ammal Public School CBSE, Mandapam - Madurai By - Pass Road, Peravoor, Ramanathapuram.		
Sample / Lab No	: DWTL/2026/27993		
Sample Name	: Water - Drinking Water		
Sample Description	: Clear, Colorless , Liquid		
Sample Source	: RO Water		
Sample Submitted by	: Customer - Mr.Dharmar		
Location & Date	: Syed Ammal Public School CBSE & 21.01.2026		
Sample Container	: Plastic – Good Condition		
Quantity of sample Received	: 2 Litre	Sample Condition on Receipt	: Good
Sample Received On	: 21.01.2026	Environmental Condition Temp °C	: 23 – 27 °C
Test Commenced on	: 21.01.2026	Test Completed on	: 22.01.2026

S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25°C	--	IS 3025: Part 11: 2022	7.88	6.5-8.5	No Relaxation
2	Total Hardness as CaCO <sub>3</sub>	mg/L	IS 3025: Part 21: 2009 (RA:2023)	8	200	600
3	Total Alkalinity as CaCO <sub>3</sub>	mg/L	IS 3025: Part 23: 2023	12	200	600
4	Chloride as Cl	mg/L	IS 3025: Part 32: 1988 (RA:2019)	18	250	1000
5	Sulphate as SO <sub>4</sub>	mg/L	IS 3025: (Part 24/Sec 1): 2022 – Turbidity Method	5	200	400
6	Nitrate as NO <sub>3</sub>	mg/L	IS 3025: (Part 34/Sec-1): 2023 – Screening Method	0	45	No Relaxation
7	Fluoride as F	mg/L	IS 3025: (Part 60/Sec-1): 2023 - SPADNS Method,	0.2	1.0	1.5

**Remark:** The tested sample conformed to IS: 10500:2012 (RA: 2023) Drinking water Acceptable Limit/ Permissible Limit specification with respect to above tested parameters.

---End of Report----

Reviewed and Authorised by  
V. Muthukrishnan - Assistant Executive Engineer

- The test results relate only to the items tested.
- The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- The test items will not be retained for more than 15 days from the date of issue of the test report.
- The result applied to the sample as received basis.



## DISTRICT WATER TESTING LABORATORY

OM Sakthi Nagar, 1st Street, Near VAO Office,

Ramanathapuram – 623 504., E-mail: ramnaddistrictlab@gmail.com

## TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	DWTL/TR/2026/27993-2	Report Issue Date :	22.01.2026	Page No : 1 of 2
Invoice Details:	307/Dt.21.01.2026/Amt.Rs.1180 / -			

Client Name & Address Contact No / Email.ID	: Syed Ammal Public School CBSE, Mandapam - Madurai By - Pass Road, Peravoor, Ramanathapuram.		
Sample / Lab No	DWTL/2026/27993		
Sample Name	: Water - Drinking Water		
Sample Description	: Clear, Colorless , Liquid		
Sample Source	RO Water		
Sample Submitted by	: Customer - Mr.Dharmar		
Location & Date	: Syed Ammal Public School CBSE & 21.01.2026		
Sample Container	: Plastic – Good Condition		
Quantity of sample Received	: 2 Litre	Sample Condition on Receipt	: Good
Sample Received On	: 21.01.2026	Environmental Condition Temp °C	: 23 – 27 °C
Test Commenced on	: 21.01.2026	Test Completed on	: 22.01.2026

Sl.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	Appearance	--	Visual	Clear	--	--
2	Odour	--	IS 3025: Part 5: 2018	None	--	--
3	Turbidity	NTU	IS 3025: Part 10: 2023	0	1	5
4	Total Dissolved Solids	mg/L	IS 3025: Part 16: 2023	58	500	2000
5	EC @ 25°C	µS/cm	IS 3025: Part 14: 2013	83	--	--
6	P- Alkalinity as CaCO <sub>3</sub>	mg/L	IS 3025: Part 23: 2023	0	--	--
7	Calcium as Ca	mg/L	IS 3025: Part 40: 1991	2	75	200
8	Magnesium as Mg	mg/L	IS 3025: Part 46: 2023	1	30	100
9	Iron as Fe mg/L	mg/L	IS 3025 (Part 53): 2024	0	0.3	No Relaxation
10	Manganese as Mn	mg/L	IS 3025 (Part 59): 2023	0	0.1	0.3

*[Signature]*  
Correspondent  
Syed Ammal Public School  
Peravoor,  
Ramanathapuram.

*[Signature]*  
Reviewed and Authorised by  
V. Muthukrishnan - Assistant Executive Engineer

- The test results relate only to the sample tested.
- The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- The test items will not be retained for more than 15 days from the date of issue of the test report.
- The result applied to the sample as received basis.

*[Signature]*  
AD  
Peravoor

Issue N / Date	01/01.09:2024	Amend .No / Date	00/-	Page No	1 of 2
----------------	---------------	------------------	------	---------	--------



**TAMILNADU WATER SUPPLY AND DRAINAGE BOARD**  
**DISTRICT WATER TESTING LABORATORY**  
**OM Sakthi Nagar, 1st Street, Near VAO Office,**  
**Ramanathapuram – 623 504., E-mail: ramnaddistrictlab@gmail.com**

**TEST REPORT**


Doc.No: DWTL/FORM/7.8/01


Report No:	DWTL/TR/2026/27993-2	Report Issue Date :	22.01.2026	Page No : 2 of 2
Invoice Details:	307/Dt.21.01.2026/Amt.Rs.1180 /-			

S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
11	Ammonia as NH <sub>3</sub>	mg/L	IS 3025 (Part 34) : 2023	0	0.5	No relaxation
12	Nitrite as NO <sub>2</sub>	mg/L	IS 3025 (Part 34/Sec-1) : 2023	0	--	--
13	Phosphate as PO <sub>4</sub>	mg/L	IS 3025 (Part 31/Sec-1) : 2022	0	--	--
14	Oxygen Observed in 4 hrs.as O <sub>2</sub> (Tidy's Test)	mg/L	IS 3025 (Part 63) : 2007	0.20	--	--
15	Residual Chlorine	mg/L	IS 3025 (Part 26) : 2007	0	0.2	1.0
<b>Bacteriological Test</b>						
1	Standard Plate Count	CFU / 1ml	APHA (24th Edn) -9215B - 2023	--	--	--
2	Total coliform	CFU / 100 ml	IS 15185 : 2016- RA : 2021	--	--	--
3	Fecal coliform	CFU / 100 ml	IS 15185 : 2016- RA : 2021	--	--	--
4	E. coli	CFU / 100 ml	IS 15185 : 2016- RA : 2021	--	--	--

**Remark:** The tested sample conformed to IS: 10500:2012 (RA: 2023) Drinking water Acceptable Limit/ Permissible Limit specification with respect to above tested parameters.

---End of Report----

  
**Correspondent**  
**Syed Ammal Public School,**  
**Peravoor,**  
**Ramanathapuram.**

  
**Principal**  
**Syed Ammal Public School,**  
**Peravoor,**  
**Ramanathapuram.**